

Minimum Controls		Code Provision
Manual Control Device		C405.2.5, C405.2.2.2
Occupancy Sensor		
	Partial ON	C405.2.1.1
	Full OFF	C405.2.1
	Partial OFF	C405.2.1
Daylight Response		C405.2, C405.2.6.1, Exception C405.2.3.1